



Wastewater Service Line Inspection Form

Tapping into the mainline is **NOT** permitted between October 15 and April 15

Inspections are **NOT** permitted between October 15 and April 15

Call 970-349-7575 x104 to schedule an inspection at least 48 hours in advance. Inspections occur Mon-Thur only

Address:

Contractor/Contact:

Service Line Size:

Pipe Material:

Trench Depth:
*Minimum 7' deep

Type of Bedding:

Required Tracer Wire: Yes
Required Green Utility Marking Tape: Yes
Insulation Variance: Yes/No

Gradient (2%-30% limits):

| | |
|--|---|
| Number of Clean-outs: <input style="width: 90%;" type="text"/> | Distance Between Clean-outs: <input style="width: 90%;" type="text"/> |
| *First clean-out must be no more than 100 feet from building and no more than 100 feet apart | |

Saddle-Tap Connection: Connections must be at least ten feet from a manhole and must tap into the main with a saddle tap horizontally to the main (3 or 9 o'clock).

Wye tap connections can be at 22° or 45° angles.

Main Line Cross Section

Saddle-Tap Horizontal to Main

FLOW →

Wye-Tap 22° or 45°

To be completed by MCBWSD Inspector.

MCBWSD Inspector:

Date of Inspection:

Comments: